




序号	报告编号	发布日期	结论	影像资料
26	GX-B1310/21-5-22216	2022/8/8	合格	
27	GX-B1310/21-5-22215	2022/8/8	合格	
28	GX-B1310/21-5-22217	2022/8/8	合格	
29	GX-B1382/21-5-22017	2022年8月4日	合格	

30	GX-B1495/20-5-221663~221666	2022/8/8	<p>本次共检高压开关柜4台，4台高压开关柜所检项目合格。</p>	 <p>2022/6/24</p>
31	GX-B1321/20-5-22541~22543	2022/8/8	<p>本次共检验电力电缆3条，3条电力电缆合格。</p>	 <p>2022/6/24</p>
32	GX-B1314/20-5-22022~22024	2022. 8. 9	所检项目合格	 <p>2022/7/12</p>

33	GX-B1306/21-5-22064	2022/8/9	所检项目合格。	
34	GX-B1306/21-5-22065	2022/8/9	所检项目合格。	

35	GX-B1306/21-5-22066	2022/8/9	所检项目合格	
36	GX-B1306/21-5-22067	2022/8/9	所检项目合格	

37	GX-B1314/20-5-22022~22024	2022. 8. 9	所检项目合格	
38	GX-B1312/20-5-22451~22452	2022. 8. 9	所检项目合格	
39	GX-B1312/20-5-22453~22461	2022. 8. 9	所检项目合格	

40	GX-B1312/20-5-22471~22484	2022. 8. 9	所检项目合格	
41	GX-B1312/20-5-22462~22470	2022. 8. 9	所检项目合格	


42	GX-B1598/21-5-22001	2022-8-9	实测钢丝绳有效截面积损失百分比最大为4.17%，小于5%为正常。	
43	GX-B1598/21-5-22002	2022-8-9	实测钢丝绳有效截面积损失百分比最大为3.91%，小于5%为正常。	



44	GX-B1598/21-5-22003	2022-8-9	实测钢丝绳有效截面积损失百分比最大为3.78%，小于5%为正常。		
45	GX-B1598/21-5-22004	2022-8-9	实测钢丝绳有效截面积损失百分比最大为4.87%，小于5%为正常。		

46	GX-B1598/21-5-22005	2022-8-9	实测钢丝绳有效截面积损失百分比最大为3.67%，小于5%为正常。	
47	GX-B1598/21-5-22006	2022-8-9	实测钢丝绳有效截面积损失百分比最大为3.23%，小于5%为正常。	


48	GX-B1598/21-5-22007	2022-8-9	实测钢丝绳有效截面积损失百分比最大为4.02%，小于5%为正常。	
49	GX-B1598/21-5-22008	2022-8-9	实测钢丝绳有效截面积损失百分比最大为4.82%，小于5%为正常。	

50	GX-B1598/21-5-22009	2022-8-9	实测钢丝绳有效截面积损失百分比最大为3.78%，小于5%为正常。	
51	GX-B1598/21-5-22010	2022-8-9	实测钢丝绳有效截面积损失百分比最大为4.48%，小于5%为正常。	

52	GX-B1598/21-5-22011	2022-8-9	实测钢丝绳有效截面积损失百分比最大为4.39%，小于5%为正常。	
53	GX-B1598/21-5-22012	2022-8-9	实测钢丝绳有效截面积损失百分比最大为3.86%，小于5%为正常。	

54	GX-B1598/21-5-22013	2022-8-9	实测钢丝绳有效截面积损失百分比最大为2.87%，小于5%为正常。			
55	GX-B1598/21-5-22014	2022-8-9	实测钢丝绳有效截面积损失百分比最大为3.55%，小于5%为正常。			

56	GX-B1598/21-5-22015	2022-8-9	实测钢丝绳有效截面积损失百分比最大为2.41%，小于5%为正常。	
57	GX-B1323/21-5-22152~22157	2022. 8. 9	所检项目合格	
58	GX-B1323/21-5-22145~22151	2022. 8. 9	所检项目合格	

59	GX-B1495/20-5-221548~221580	2022. 8. 9	所检项目合格	
60	GX-B1495/20-5-221646~221662	2022. 8. 9	所检项目合格	
61	GX-B1495/20-5-221607~221645	2022. 8. 9	所检项目合格	

62	GX-B1495/20-5-221581~221606	2022. 8. 9	所检项目合格	
----	-----------------------------	------------	--------	---



